



(Responsible Individual)

(Company Name)

I, , from

verify that the information provided below is accurate, to the best of my knowledge.

CREDIT COMPLIANCE

(Please complete the color coded criteria(s) based on the option path selected)

Please select the appropriate compliance path option

Option 1 (Pg 2): Performance Rating Method, ASHRAE 90.1-2004 Appendix G or equivalent (up to 10 points possible)

Option 2 (Pg 14): ASHRAE Advanced Energy Design Guide for Small Office Buildings 2004 (4 points)

Option 3 (Pg 14): Advanced Buildings Benchmark™ Version 1.1, Basic Criteria & Prescriptive Measures (1 point)



OPTION 1: PERFORMANCE RATING METHOD

I confirm that the energy simulation software used for this project has all capabilities described in EITHER section 'G2 Simulation General Requirements' in Appendix G of ASHRAE 90.1-2004 OR the analogous section of the alternative qualifying energy code used.

I confirm that the baseline building and proposed building in this project's energy simulation runs use the assumptions and modeling methodology described in EITHER Appendix G of ASHRAE 90.1-2004 OR the analogous section of the alternative qualifying energy code used.

Complete the following sections to document compliance using Option 1:

- Section 1.1 - General Information
- Section 1.2 - Space Summary
- Section 1.3 - Advisory Messages
- Section 1.4 - Comparison of Proposed Design Versus Baseline Design Energy Model Inputs
- Section 1.5 - Energy Type Summary
- Section 1.6 - On-Site Renewable Energy *(if applicable)*
- Section 1.7 - Exceptional Calculation Measure Summary *(if applicable)*
- Section 1.8 - Performance Rating Method Compliance Report

Section 1.1 - General Information

Provide the following data for your project

Simulation Program:	<input type="text" value="Trane TRACE 700"/>	Quantity of Stories:	<input type="text" value="4"/>
Principal Heating Source:	<input type="text" value="Fossil Fuel"/>	Weather File:	<input type="text" value="New Orleans, LA"/>
Energy Code Used:	<input type="text" value="ASHRAE 90.1-2004 Appendix G"/>	Climate Zone:	<input type="text" value="2A"/>
New Construction Percent:	<input type="text" value="100 %"/>	Existing Renovation Percent:	<input type="text" value="0 %"/>

Enter the Target Finder score for your building from the Energy Star website (http://www.energystar.gov/index.cfm?fuseaction=target_finder.&CFID=154897). The score has no bearing on the number of EAc1 points earned. Use the following process to evaluate the Target Finder score:

1. Enter the facility information
2. Enter the facility characteristics. Select each primary and secondary space type that applies to the project. Then complete the required information for each space type.
4. Enter the total energy use per energy source for your project based on the totals reflected in the Proposed Design energy simulation output report.

Target Finder Score:



Section 1.2 - Space Summary

Provide the space summary for your project
(click "CLEAR" to clear the contents of any row All numeric entries must be entered as whole numbers without commas):

Table 1.2 - Space Summary				
Building Use (Occupancy Type)	Conditioned Area (sf)	Unconditioned Area (sf)	Total Area (sf)	
Laboratory	14,446	0	14,446	<input type="button" value="CLEAR"/>
Office	8,023	0	8,023	<input type="button" value="CLEAR"/>
Conference	3,875	0	3,875	<input type="button" value="CLEAR"/>
Break Areas	1,291	0	1,291	<input type="button" value="CLEAR"/>
Lobbies	2,646	0	2,646	<input type="button" value="CLEAR"/>
Restrooms	1,553	0	1,553	<input type="button" value="CLEAR"/>
Mechanical/Electrical/Communications	7,743	1,569	9,312	<input type="button" value="CLEAR"/>
Storage/Janitor/Stair/Elevator	724	2,680	3,404	<input type="button" value="CLEAR"/>
Lab Shell	7,197	0	7,197	<input type="button" value="CLEAR"/>
Office Shell	3,484	2,177	5,661	<input type="button" value="CLEAR"/>
Corridors	4,774	0	4,774	<input type="button" value="CLEAR"/>
Total:	55,756	6,426	62,182	

Section 1.3 - Advisory Messages

Complete the following information from the simulation output files (all entries should be entered as whole numbers, without commas)

TABLE 1.3 - Advisory Messages	Proposed Building	Baseline Building (0 deg. rotation)	Difference
Number of hours heating loads not met:	<input type="text" value="0"/>	<input type="text" value="0"/>	0
Number of hours cooling loads not met:	<input type="text" value="0"/>	<input type="text" value="0"/>	0
Number of warning messages:	<input type="text" value="0"/>	<input type="text" value="0"/>	0
Number of error messages:	<input type="text" value="0"/>	<input type="text" value="0"/>	0
Number of defaults overridden:	<input type="text" value="0"/>	<input type="text" value="0"/>	0



Section 1.4 - Comparison of Proposed Design Versus Baseline Design Energy Model Inputs

Use **Table 1.4** to document the Baseline and Proposed design energy model inputs for your project. Include descriptions for:

1. Exterior wall, underground wall, roof, floor, and slab assemblies including framing type, assembly R-values, assembly U-factors, and roof reflectivity when modeling cool roofs. (Refer to ASHRAE 90.1 Appendix A)
2. Fenestration types, assembly U-factors (including the impact of the frame on the assembly), SHGCs, and visual light transmittances, overall window-to-gross wall ratio, fixed shading devices, and automated movable shading devices.
3. Interior lighting power densities, exterior lighting power, process lighting power, and lighting controls modeled for credit.
4. Receptacle equipment, elevators or escalators, refrigeration equipment, and other process loads.
5. HVAC system information including types and efficiencies, fan control, fan supply air volume, fan power, economizer control, demand control ventilation, exhaust heat recovery, pump power and controls, and any other pertinent system information. (Include the ASHRAE 90.1-2004 Table G.3.1.1B Baseline System Number).
6. Domestic hot water system type, efficiency and storage tank volume.
7. General schedule information

Documentation should be sufficient to justify the energy and cost savings numbers reported in the Performance Rating Table.

(Click "CLEAR" to clear the contents of any row.)

Model Input Parameter	Proposed Design Input	Baseline Design Input	
Exterior Wall Construction	Precast concrete panel with continuous foam insulation, assembly U-value = 0.053	ASHRAE 90.1-2004 Table 5.5-2, steel-framed wall, assembly U-value = 0.124	CLEAR
Roof Construction	Modified bituminous sheets and polyisocyanurate board insulation, assembly U-value = 0.04	ASHRAE 90.1-2004 Table 5.5-2, insulation entirely above deck, assembly U-value = 0.063	CLEAR
Floor/Slab Construction	Unheated concrete slab, F-factor = 0.5	ASHRAE 90.1-2004 Table 5.5-2, unheated slab, F-factor = 0.73	CLEAR
Window-to-gross wall ratio	42.1%	40%	CLEAR
Fenestration type	Insulating double-pane coated Low-E type	ASHRAE 90.1-2004 Table 5.5-2, 30.1-40% of wall area	CLEAR
Fenestration U-factor	Center-of-glass U-value = 0.26; Assembly U-value = 0.47	1.22	CLEAR
Fenestration SHGC - North	0.287	0.25	CLEAR
Fenestration SHGC - Non-North	0.287	0.25	CLEAR
Fenestration Visual Light Transmittance	36%	N/A	CLEAR
Shading Devices	Horizontal and vertical fins and overhangs on curtainwall glazing	None	CLEAR
			CLEAR
Interior Lighting Power Density (W/sf)	Calculated according to Space-by-Space Method. Overall building weighted average: 0.84 W/sf. Individual space types: Laboratory: 1.197 W/sf	Calculated according to Space-by-Space Method. Overall building weighted average: 1.11 W/sf. Individual space types: Laboratory: 1.4 W/sf	CLEAR



TABLE 1.4 - Comparison of Proposed Design Versus Baseline Design

Model Input Parameter	Proposed Design Input	Baseline Design Input	
Daylighting Controls	Provided for southwest-facing Canal St. office with almost 100% glazing	None	CLEAR
Other Lighting Control Credits	10% power adjustment taken for occupancy sensors; see uploaded summary report for details.	None	CLEAR
Exterior Lighting Power (kW)	Tradeable surfaces: 3.3 kW. There are no non-tradeable surfaces in the project.	Tradeable surfaces: 5.1 kW. There are no non-tradeable surfaces in the project.	CLEAR
Process Lighting (kW)	None	None	CLEAR
Receptacle Equipment Power Density (W/sf)	Labs = 5 W/sf; elec/comm rooms = 20 W/sf; all other spaces = 0.75W/sf	Same as proposed	CLEAR
			CLEAR
Primary HVAC System Type	Water-cooled centrifugal chillers with variable frequency drives; variable-volume air handling units; copper fin-tube hot water boilers; terminal units +	Table G3.1.1B System #5 - Packaged rooftop variable air volume with reheat; direct-expansion cooling; fossil fuel boiler heating +	CLEAR
Other HVAC System Type	Direct-expansion split-systems for comm room cooling	Table G3.1.1B System #3 - Packaged constant-volume rooftop air conditioner; direct-expansion cooling; fossil fuel furnace heating +	CLEAR
Fan Supply Volume	57,500 CFM, per schedules on the design documents	64,323 CFM, as calculated by system simulation, see uploaded summary report for details	CLEAR
Fan Power	Per schedules on the design documents	Calculated in accordance with Section G3.1.2.9, see uploaded summary report for details	CLEAR
Economizer Control	No economizer is provided	No economizer is required or provided	CLEAR
Demand Control Ventilation	Provided for the air handling system serving the large conference room only	None	CLEAR
Unitary Equipment Cooling Efficiency	14 SEER; 15 tons total capacity	RTU-1A: 17.3 tons; size range: >135,000 Btuh and <240,000 Btuh. RTU-1B: 26 tons; size range: >240,000 Btuh and <760,000 Btuh. RTU-2: 115 tons +	CLEAR
Unitary Equipment Heating Efficiency	8.5 HSPF	80% for all units, per Table 6.8.1E. RTU-2: 668 MBH capacity. RTU-3: 651 MBH capacity. Split Systems: 100 MBH capacity +	CLEAR
Chiller parameters	Full load kW/ton = 0.66; NPLV = 0.459; 56 deg. entering water temperature, 42 deg. leaving water temperature; 500 tons total capacity +	N/A	CLEAR
Chilled water loop & pump parameters	Variable-flow primary with minimum flow bypass	N/A	CLEAR
Boiler parameters	Copper fin-tube type, 81% efficient; 3000 MBH total capacity	80% efficient per ASHRAE 90.1-2004 Table 6.8.1F. Each boiler: 500 MBH capacity. Total heating capacity (including unitary heating equipment) +	CLEAR
Hot water loop & pump parameters	Primary-secondary system with constant flow through boiler loop and variable flow through building distribution loop +	Variable flow primary system with pumps riding their curves to vary flow.	CLEAR
Cooling tower parameters	4 deg. approach, 10 deg. range, with variable frequency drives controlling tower fans	N/A	CLEAR
Condenser water loop & pump parameters	Constant speed pumps with cooling tower bypass	N/A	CLEAR
			CLEAR



Section 1.5 - Energy Type Summary

List the energy types used by your project (i.e. electricity, natural gas, purchased chilled water or steam, etc.) for either the Baseline or Proposed design. Also describe the utility rate used for each energy type (i.e. Feswick County Electric LG-S), as well as the units of energy used, and the units of demand used. (Click "CLEAR" to clear the contents of any row):

TABLE 1.5 - Energy Type Summary

Energy Type	Utility Rate Description	Units of Energy	Units of demand	
Electricity	Entergy New Orleans	kWh	kW	<input type="button" value="CLEAR"/>
Natural Gas	Entergy New Orleans	therms	MBH	<input type="button" value="CLEAR"/>
				<input type="button" value="CLEAR"/>
				<input type="button" value="CLEAR"/>

Energy Units:

- 1 kBtu = 1,000 Btu
- 1 kWh = 3.412 kBtu
- 1 therm = 100 kBtu
- 1 MBtu = 1,000 kBtu
- 1 MWh = 3,412 kBtu
- 1 ton hr = 12 kBtu

Demand Units

- 1 MBH = 1,000 Btu/h
- 1 kW = 3.412 MBH
- 1 MMBtuh = 1,000 MBH
- 1 ton = 12 MBH



Section 1.6 - On-Site Renewable Energy

If the project does not include on-site renewable energy, skip to Section 1.7

The project includes On-Site Renewable Energy

How is the on-site renewable energy cost calculated?

This form will automatically calculate the *Renewable Energy Cost* based on the "virtual" energy rate from the proposed design energy model results. This form will subtract the *Renewable Energy Cost* from the proposed design energy model results to calculate the *Proposed Building Performance Rating*. (You do NOT need to fill out the "Renewable Energy Cost" field in Table 1.6 below)

Renewable Energy Cost for each on-site renewable source is analyzed separately from the energy model based on local utility rate structures. The Renewable Energy Cost for each renewable source is reported in Table 1.6 below, This form will subtract the reported Renewable Energy Cost from the proposed design energy model results to calculate the Proposed Building Performance Rating.

On-site renewable energy is modeled directly in the energy model. *Renewable Energy Cost* is already credited in the proposed design energy model results (i.e. the energy model already reflects zero cost for on-site renewable energy, and this form will NOT subtract the *Renewable Energy Cost* a second time).

Indicate the on-site renewable energy source(s) used, the backup energy type for each source (i.e. the fuel that is used when the renewable energy source is unavailable - ASHRAE 90.1-2004, Section G2.4), the rated capacity for the source, and the annual energy generated from each source.

TABLE 1.6 - Renewable Energy Source Summary

Renewable Source	Backup Energy Type	Annual Energy Generated	Rated Capacity	Renewable Energy Cost	
					CLEAR
					CLEAR



Section 1.7 - Exceptional Calculation Measure Summary

(If the energy analysis does not include exceptional calculation methods, skip to Section 1.8)

The energy analysis includes exceptional calculation method(s) (ASHRAE 90.1-2004, G2.5)

How is the exceptional calculation measure cost savings determined?

This form will automatically calculate the exceptional calculation measure cost savings based on the "virtual" energy rate from the proposed design energy model results. This form will subtract this cost savings from the proposed design energy model results to calculate the *Proposed Building Performance Rating*.

Exceptional calculation measure cost for each exceptional calculation measure is analyzed based on local utility rate structures. The *cost savings* for each exceptional calculation is reported below, This form will subtract the reported exceptional calculation cost savings from the proposed design energy model results to calculate the *Proposed Building Performance Rating*.

For each exceptional calculation method employed, document the predicted energy savings by energy type , the energy cost savings (if option 2 above is selected), and a narrative explaining the exceptional calculation method performed, and theoretical or empirical information supporting the accuracy of the method. Reference any applicable Credit Interpretation Rulings. [Note: if an end-use has an energy loss rather than an energy savings, enter it as a negative number]

Exceptional Calculation Measure Short Description:

Energy Type(s)	Annual Energy Savings by Energy Type	Annual Cost Savings	Exceptional Calculation Measure Narrative:
<input type="text"/>	<input type="text"/>	<input type="text"/>	
<input type="text"/>	<input type="text"/>	<input type="text"/>	
<input type="text"/>	<input type="text"/>	<input type="text"/>	
<input type="text"/>	<input type="text"/>	<input type="text"/>	

Exceptional Calculation Measure Short Description:

Energy Type(s)	Annual Energy Savings by Energy Type	Annual Cost Savings	Exceptional Calculation Measure Narrative:
<input type="text"/>	<input type="text"/>	<input type="text"/>	
<input type="text"/>	<input type="text"/>	<input type="text"/>	
<input type="text"/>	<input type="text"/>	<input type="text"/>	
<input type="text"/>	<input type="text"/>	<input type="text"/>	



Section 1.8 - Performance Rating Method Compliance Report (Option 1 Compliance Only)

In **Table 1.8.1**, list each energy end use for your project (including all end uses reflected in the baseline and proposed designs). Then check whether the end-use is a process load, select the energy type, and list the energy consumption and peak demand for each end-use for all four Baseline Design orientations. In **Table 1.8.1(b)** indicate the total baseline energy cost for each energy type for all four Baseline Design orientations. If either the baseline or proposed design uses more than one energy type for a single end use (i.e. electric resistance reheat, and central natural gas heating), enter each energy type as a separate end use (i.e. *Heating - Electric*, and *Heating, NG*).

Fill out the Proposed Design energy consumption and peak demand for each end use in **Table 1.8.2**. In **Table 1.8.2 (b)** indicate the total proposed energy cost for each energy type. [Note: Process loads for the proposed design must equal those listed in the Baseline design. Any process load energy savings for the project must be reported in Section 1.7.]

(Click "CLEAR" to clear the contents of any end use)

End Use	Process?	Baseline Design Energy Type	Units of Annual Energy & Peak Demand	Baseline (0° rotation)	Baseline (90° rotation)	Baseline (180° rotation)	Baseline (270° rotation)	Baseline Design	
Interior Lighting	<input type="checkbox"/>	Electricity	Energy Use (kWh)	218,501.3	218,501.3	218,501.3	218,501.3	218,501.3	CLEAR
			Demand (kW)	62.9	62.9	62.9	62.9	62.9	
Exterior Lighting	<input type="checkbox"/>	Electricity	Energy Use (kWh)	24,199.5	24,199.5	24,199.5	24,199.5	24,199.5	CLEAR
			Demand (kW)	5.1	5.1	5.1	5.1	5.1	
Space Heating	<input type="checkbox"/>	Natural Gas	Energy Use (therms)	7,128	7,345	7,425	7,242	7,285	CLEAR
			Demand (MBH)	527	531	520	529	526.8	
Space Cooling	<input type="checkbox"/>	Electricity	Energy Use (kWh)	676,730.2	675,675.2	678,312.8	679,133.4	677,462.9	CLEAR
			Demand (kW)	330.1	329.8	326	329.8	328.9	
Pumps	<input type="checkbox"/>	Electricity	Energy Use (kWh)	6,066.6	6,037.3	6,037.3	6,037.3	6,044.6	CLEAR
			Demand (kW)	.6	.6	.6	.6	.6	
Heat Rejection	<input type="checkbox"/>	Electricity	Energy Use (kWh)	240,552.7	239,732.1	237,006.5	239,204.6	239,124	CLEAR
			Demand (kW)	28.1	28.1	27.8	28.1	28	
Fans - Interior	<input type="checkbox"/>	Electricity	Energy Use (kWh)	188,796.3	185,689.8	190,906.4	194,687.1	190,019.9	CLEAR
			Demand (kW)	42.8	42.8	42.8	42.8	42.8	
Space Heating Elec. Accessories	<input type="checkbox"/>	Electricity	Energy Use (kWh)	4,396.1	4,396.1	4,396.1	4,396.1	4,396.1	CLEAR
			Demand (kW)	.6	.6	.6	.6	.6	
Service Water Heating	<input checked="" type="checkbox"/>	Natural Gas	Energy Use (therms)	4,566.2	4,566.2	4,566.2	4,566.2	4,566.2	CLEAR
			Demand (MBH)	125	125	125	125	125	
Receptacle Equipment	<input checked="" type="checkbox"/>	Electricity	Energy Use (kWh)	585,107.9	585,107.9	585,107.9	585,107.9	585,107.9	CLEAR
			Demand (kW)	75.6	75.6	75.6	75.6	75.6	



Table 1.8.1 - Baseline Performance - Performance Rating Method Compliance

End Use	Process?	Baseline Design Energy Type	Units of Annual Energy & Peak Demand	Baseline (0° rotation)	Baseline (90° rotation)	Baseline (180° rotation)	Baseline (270° rotation)	Baseline Design	
Interior Lighting (Process)	<input checked="" type="checkbox"/>	Electricity	Energy Use (kWh)						CLEAR
			Demand (kW)						
Refrigeration	<input checked="" type="checkbox"/>	Electricity	Energy Use (kWh)						CLEAR
			Demand (kW)						
Data Center Equipment	<input checked="" type="checkbox"/>	Electricity	Energy Use (kWh)						CLEAR
			Demand (kW)						
Cooking	<input checked="" type="checkbox"/>		Energy Use						CLEAR
			Demand						
Elevators & Escalators	<input checked="" type="checkbox"/>	Electricity	Energy Use (kWh)	41,610	41,610	41,610	41,610	41,610	CLEAR
			Demand (kW)	10	10	10	10	10	
	<input type="checkbox"/>		Energy Use						CLEAR
			Demand						
Baseline Energy Totals:			Total Annual Energy Use (MBtu/year)	7,946	7,950	7,976	7,981	7,963	
			Annual Process Energy (MBtu/year)					2,595	

Note: Process Cost equals at least 25% of Baseline Performance, as required for showing credit compliance.

Table 1.8.1(b) - Baseline Energy Costs

Energy Type	Baseline Cost (0° rotation)	Baseline Cost (90° rotation)	Baseline Cost (180° rotation)	Baseline Cost (270° rotation)	Baseline Building Performance
Electricity	\$154,871	\$154,218	\$154,376	\$155,111	\$154,644
Natural Gas	\$10,537	\$10,708	\$10,771	\$10,627	\$10,660
Total Baseline Costs:	\$165,408	\$164,926	\$165,147	\$165,738	\$165,304

Table 1.8.2 - Performance Rating Table - Performance Rating Method Compliance

End Use	Process?	Proposed Design Energy Type	Proposed Design Units	Proposed Building Results	Baseline Building Units	Baseline Building Results	Percent Savings
Interior Lighting		Electricity	Energy Use (kWh)	159,490.4	Energy Use (kWh)	218,501.3	27 %
			Demand (kW)	44.7	Demand (kW)	62.9	29 %



Table 1.8.2 - Performance Rating Table - Performance Rating Method Compliance

End Use	Process?	Proposed Design Energy Type	Proposed Design Units	Proposed Building Results	Baseline Building Units	Baseline Building Results	Percent Savings
Exterior Lighting		Electricity	Energy Use (kWh)	15,658.5	Energy Use (kWh)	24,199.5	35.3 %
			Demand (kW)	3.3	Demand (kW)	5.1	35.3 %
Space Heating		Natural Gas	Energy Use (therms)	4,897	Energy Use (therms)	7,285	32.8 %
			Demand (MBH)	288	Demand (MBH)	526.8	45.2 %
Space Cooling		Electricity	Energy Use (kWh)	338,321.2	Energy Use (kWh)	677,462.9	50.1 %
			Demand (kW)	191.6	Demand (kW)	328.9	41.8 %
Pumps		Electricity	Energy Use (kWh)	133,024.9	Energy Use (kWh)	6,044.6	-2,100.73%
			Demand (kW)	44.5	Demand (kW)	.6	-7,450 %
Heat Rejection		Electricity	Energy Use (kWh)	43,521	Energy Use (kWh)	239,124	81.8 %
			Demand (kW)	18.2	Demand (kW)	28	34.7 %
Fans - Interior		Electricity	Energy Use (kWh)	191,287.4	Energy Use (kWh)	190,019.9	-7 %
			Demand (kW)	98.7	Demand (kW)	42.8	-130.1 %
Space Heating Elec. Accessories		Electricity	Energy Use (kWh)	0	Energy Use (kWh)	4,396.1	0 %
			Demand (kW)	0	Demand (kW)	.6	0 %
Service Water Heating	X	Natural Gas	Energy Use (therms)	4,566.2	Energy Use (therms)	4,566.2	0 %
			Demand (MBH)	125	Demand (MBH)	125	0 %
Receptacle Equipment	X	Electricity	Energy Use (kWh)	585,107.9	Energy Use (kWh)	585,107.9	0 %
			Demand (kW)	75.6	Demand (kW)	75.6	.4 %
Interior Lighting (Process)	X	Electricity	Energy Use (kWh)		Energy Use (kWh)		0 %
			Demand (kW)		Demand (kW)		0 %
Refrigeration	X	Electricity	Energy Use (kWh)		Energy Use (kWh)		0 %
			Demand (kW)		Demand (kW)		0 %
Data Center Equipment	X	Electricity	Energy Use (kWh)		Energy Use (kWh)		0 %
			Demand (kW)		Demand (kW)		0 %
Cooking	X		Energy Use		Energy Use		0 %
			Demand		Demand		0 %
Elevators & Escalators	X	Electricity	Energy Use (kWh)	41,610	Energy Use (kWh)	41,610	0 %
			Demand (kW)	10	Demand (kW)	10	0 %
			Energy Use		Energy Use		0 %
			Demand		Demand		0 %
Energy Totals:			Total Annual Energy Use (MBtu/year)	6,092		7,963	23.5 %
			Annual Process Energy (MBtu/year)	2595		2,595	0 %



Table 1.8.2(b) - Energy Cost and Consumption by Energy Type - Performance Rating Method Compliance

Energy Type	Proposed Design		Baseline Design		Percent Savings	
	Energy Use	Cost	Energy Use	Cost	Energy Use	Cost
Electricity	1,508,018 kWh	\$120,456	1,986,461 kWh	\$154,644	24.1 %	22.1 %
Natural Gas	9,463 therms	\$8,785	11,851 therms	\$10,660	20.2 %	17.6 %
	0		0		0 %	0 %
	0		0		0 %	0 %
Subtotal (Model Outputs):	6,092 (MBtu/year)	\$129,241	7,963 (MBtu/year)	\$165,304	23.5 %	21.8 %
On-Site Renewable Energy	Energy Generated	Renewable Energy Cost				
Exceptional Calculations	Energy Savings	Cost Savings				
	Proposed Design		Baseline Design		Percent Savings	
	Energy Use	Cost	Energy Use	Cost	Energy	Cost
Total:	6,092 (MBtu/year)	\$129,241	7,963 (MBtu/year)	\$165,304	23.5 %	21.8 %



DOCUMENTATION DESCRIPTION LOG

Please upload the compliance summaries for ASHRAE 90.1-2004 (or qualifying local energy code) and/or LEED if available from the energy simulation software used. Please also upload the energy rate tariff from the project's energy providers if the project is not using the default rates in the LEED-NC v2.2 Reference Guide.

If the software is incapable of producing the energy code or LEED compliance summaries please provide output summaries and example input summaries for both the baseline and proposed buildings that support the data entered in the template tables above.

- * Output summaries must include simulated energy consumption by end use as well as total building energy consumption and cost by energy type used in the building.
- * Example input summaries must be a sampling of model input assumptions, focusing on the most common systems present in the building. The example input summaries should be taken from the simulation software's standard input reports if available; if the software will not produce input summary reports then screen captures of representative inputs are acceptable. The example input summaries must include samples of the following input information:

1. Occupancy and usage patterns
2. Assumed envelope component sizes and traits (area, R-value, U-value, etc.)
3. Assumed mechanical equipment types and traits (capacity, efficiency, etc.)

Please note that uploaded documents should be SUMMARIES, and not large quantities of detailed data

Documentation Description Log

In the text box below, please reference the file name of each uploaded file (e.g. simulationsummary.pdf)

NOBIC Energy Analysis Summary.pdf



I have provided the appropriate supporting documentation in the document upload section of LEED Online. Please refer to the above sheets.



OPTION 2: ASHRAE ADVANCED ENERGY DESIGN GUIDE FOR SMALL OFFICE BUILDINGS, 2004

The building complies with all the prescriptive measures of the ASHRAE Advanced Energy Design Guide for Small Office Buildings 2004. The following restrictions are applicable:

The project is less than 20,000 square feet.

The project is office occupancy.

The project has fully complied with all applicable criteria as established in the Advanced Energy Design Guide for the climate zone in which the building is located

Climate zone

OPTION 3: ADVANCED BUILDINGS BENCHMARK™ VERSION 1.1

The project fully complies with the Basic Criteria and Prescriptive Measures of the Advanced Buildings Benchmark™ Version 1.1 with the exception of the following sections: 1.7 Monitoring and Trend-logging, 1.11 Indoor Air Quality, and 1.14 Networked Computer Monitor Control.

Climate zone



NARRATIVE (Optional)

Please provide any additional comments or notes regarding special circumstances or considerations regarding the project's credit approach.

The target finder score indicated in the template is not an accurate representation of this building's energy performance as compared to average buildings. "Laboratory" is not an option for space type in the Energy Star target finder. The closest alternative is "Medical Office", which implies much less energy consumption than a typical laboratory.

The project is seeking point(s) for this credit using an alternate compliance approach. The compliance approach, including references to any applicable Credit Interpretation Rulings is fully documented in the narrative above. *(Indicate the number of points documented in the "Alternative Compliance Points Documented" field below).*

Alternative Compliance Points Documented

Project Name: NOBIC

Credit: EA Credit 1: Optimize Energy Performance

Points Documented:

READY TO SAVE THIS TEMPLATE TO LEED-ONLINE? Please enter your first name, last name and today's date below, followed by your LEED-Online Username and Password associated with the Project listed above to confirm submission of this template.

<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
First Name	Last Name	Date	Username (Email Address)	Password

SAVE TEMPLATE TO LEED-ONLINE

PRINT TEMPLATE

10000451
Letter Template Version A1 .